



MANHOLE ABANDONMENT PROCEDURE:
(SEE SPECIFICATIONS FOR ADDITIONAL INFORMATION)

MANHOLES WHICH ARE TO BE ABANDONED WILL FIRST HAVE BOTH INFLUENT AND EFFLUENT LINES PLUGGED INSIDE THE MANHOLE WITH WATERTIGHT MASONRY. THE MINIMUM LENGTH OF WATER TIGHT MASONRY PLUGS WILL BE THE DIAMETER OF THE ABANDONED PIPE PLUS ONE FOOT. THE MANHOLE WILL THEN BE FILLED WITH INCOMPRESSIBLE MATERIAL (CRUSHED STONE OR AS APPROVED). TO A POINT THREE FEET 93'-0"0 BELOW THE FINISH GRADE. THE REMAINDER OF THE MANHOLE SHALL BE BROKEN DOWN AND REMOVED. THEN THE EXCAVATION SHALL BE BACKFILLED TO FINISH GRADE AS SPECIFIED UNDER TRENCH BACKFILL.

DATE: 10/19/2023

SS-D DWG. NO. 13

SCALE: NOT TO SCALE

City of Hendersonville Engineering Department
305 Williams Street
Hendersonville, NC 28792
(828) 697-3000 (office)

www.cityofhendersonville.org

MANHOLE ABANDONMENT

