



**FIRE HYDRANT  
DITCH INSTALLATION  
DETAIL**

**NOTES:**

1. SEE FIRE HYDRANT STANDARD INSTALLATION DETAIL FOR ADDITIONAL REQUIREMENTS.
2. ALL VALVES AND HYDRANTS SHALL HAVE M.J. CONNECTIONS WITH IRON RETAINING GLAND M.J. RESTRAINT.
3. FIRE HYDRANT OFFSET CONNECTOR SHALL BE PLACED AS APPROVED BY THE ENGINEER.
4. OFFSET CONNECTOR SHALL NOT BE BACK FILLED UNTIL INSPECTED AND APPROVED BY ENGINEER.

**DATE: 01/12/2019**    **WD DWG. NO. 13**

**SCALE: NOT TO SCALE**

City of Hendersonville Engineering Department  
 305 Williams Street  
 Hendersonville, NC 28792  
 (828) 697-3000 (office)  
[www.cityofhendersonville.org](http://www.cityofhendersonville.org)